



To

UNION FOAM S.p.A.

Via dell'Industria, 11

20040 BELLUSCO (MI)

Date, 31st March, 2004
RP n° 171/A
Ref. Fax dated 27.02.04

Received 11.03.04

Start tests 11.03.04

End tests 29.03.04

Page 1 of 1

T E S T R E P O R T

Subject: DETERMINATION OF THE WATER SOLUBLE CHLORIDE IONS, AMMONIA AND NITRITES CONTENTS FROM A REPRESENTATIVE SAMPLE OF EUROBATEX WHEN SUPPLIED IN THE FORM OF FLEXIBLE CELLULAR TUBE OR SHEET

<u>Sample</u>	EUROBATEX
<u>Water soluble chloride ions content</u>	0,025 %
<u>Water soluble ammonia content</u>	0,072 %
<u>Water soluble nitrites content</u>	Absent

Remark: The examined elastomeric material, marked EUROBATEX, meets the requirements of the standards DIN 1988/88 Part. 7 and EN 13468/2001.

The contained results refer only to the tested sample.

This report cannot be partially reproduced without the laboratory approval.

E. Badomer, Operator
E. Badomer



F. Casa, Director
F. Casa